

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by SIDDHARTH BHARDWAJ

(Name of Officers with designation) from ASSISTANT ENGINEER PHED

inspected the ABR FOUNDATION SCHOOL DARIGAM

(Name & Address of the school) on 17/4/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. SAM/W/26-27/R/05 dated 21/4/26

of ONE YEAR (PHED Lab) certified that

the ABR FOUNDATION SCHOOL DARIGAM (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

filed
22/04/2026

SIDDHARTH BHARDWAJ
ASSISTANT ENGINEER

To

(Name & Address of the Institution)

पवर प्रमण्डल प्रशासिकारी
पोस्ट स्वा. अ. ११६२
वासाराग

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



TC-14408

District Level Laboratory PHED, Sasaram, Rohtas
Old G.T. Road, Near Railway Station, Sasaram, (Rohtas)
eephedrohtas@gmail.com Ph.No :- 8544428572/8544428639



बिहार सरकार

TEST REPORT

Name & Address Of the Customer:-

ABR FOUNDATION SCHOOL DARIGAON
ABR Campus, Darigaon Sasaram Rohtas

Report No. : SRM/W/26-27/R/ 05
Date : 21/04/2026
Sample No. : SRM/W/26-27/05
Sample Description : Drinking Water
Sample Mark/ Location : ABR FOUNDATION SCHOOL DARIGAON
Sample Collected On : 17/04/2026
Sampling Plan & Method : IS 3025(Part 1)
Date of Performance (s) : 17/04/2026 to 21/04/2026
Ref No. Date :

Analysis Result

Sl. No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	pH	IS 3025(Part 11) : 20222	6.5-8.5	NR	7.83
2	Turbidity	IS 3025(Part 10) : 2023	1 NTU	5 NTU	1
3	TDS	IS 3025(Part 16) : 2023	500 mg/ L	2000 mg/ L	495
4	Total Hardness	IS 3025(Part 21) : 2019	200 mg/ L	600 mg/ L	340
5	Calcium	IS 3025(Part 40) : 2023	75 mg / L	200 mg/L	69
6	Magnesium	APHA 24rd Edition -3500-Mg Method B (Calculation Method) : 2023	30 mg /L	100 mg/ L	40.70
7	Iron	APHA 23rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1 mg/ L	NR	0.1
8	Chloride	IS 3025(Part 32) : 2019	250 mg/ L	1000 mg / L	28
9	Total Alkalinity	IS 3025(Part 23) : 2023	200 mg / L	600 mg / L	286
10	Fluoride	APHA 24rd Edition -4500-F Method C (Electrode Method) : 2023	1 mg / L	1.5 mg / l	0.445
11	Colour	IS 3025 (Part 4) : 2021	5	15	<1
12	Odour	IS 3025 (Part 5) : 2022	Agreeable	Agreeable	Agreeable
13	Taste	IS 3025 (Part 8) : 2023	Agreeable	Agreeable	Agreeable

Authorized

R. Kumar
Chemist
21/04/2026

D.L.L Sasaram, Rohtas,

Disclaimer:

- The result relates only to the items(S) tested
- The report shall not be reproduced except in full, without approval of the laboratory
- The reserved part of water samples (s) shall be retained for 15 Days from the date of issue of the test Report.
- The laboratory is responsible for all the information given in the report.